




1. CONCRETE SHALL BE NORMAL-CLASS N32 STANDARD STRENGTH GRADE OR HIGHER COMPLYING WITH THE REQUIREMENTS OF AS 1379. EXPOSURE CLASSIFICATIONS UP TO AND INCLUDING B1.
2. CONCRETE FRAME TO BE SET IN 5 mm MORTAR.

E				GENERAL NOTES / CROSS REFERENCES	 PRINCIPAL ROAD DESIGN ENGINEER'S DEPARTMENT	STANDARD DRAWING INLET CATCH PIT (Type 2) PIPE CULVERTS 300 TO 600 DIA						
D				1. THIS PIT IS ONLY TO BE USED FOR RURAL ROADS WITH LOW TRAFFIC VOLUMES.			APPROVED	DATE	SPEC. REF. No.	SHEET No.	DRAWING No.	AMENDMENT
C				2. PIT DIMENSIONING AND SETTING OUT DETAILS		SD 1001	<i>T. Cunningham</i>	23.9.94	705		SD 1102	A
B				3. PIT COVERS		SD 1051						
A	J.C.	12.98	AMENDMENT TO NOTE 1, CONCRETE STRENGTH GRADE.	4. ALL DIMENSIONS ARE IN MILLIMETRES								
AMEND.	Appd.	Date	AMENDMENTS									